

Water Testing Results - Astoria Middle School

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	Corrective Action Taken
Staff Lounge	AMS-001	6/13/2016	3.7 ppb	
Gym Faucet	AMS-002	6/13/2016	ND	
Kitchen Sink Cafeteria	AMS-003	6/13/2016	6.2 ppb	
Main Floor Faucet	AMS-004	6/13/2016	ND	

ND = Non Detect - Lead level is below the set detection limits