



13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 07/28/2016

Received: 07/20/2016

Sampled By:

Work Order: 6202072

**C** Astoria School District  
**L** Attn: -  
**I** 785 Alameda Ave.  
**E** Astoria OR, 97103  
**N** Phone: (503) 325-6441  
**T**



**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6202072-01</b>	<b>Sample Name:</b> Sports Hall Faucet AHS <b>Sampled:</b> 7/14/16 8:00						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	<b>51.8</b>	ppb	4.0	20 ppb	07/26/16 18:05 <b>MCLE</b>
<b>6202072-02</b>	<b>Sample Name:</b> Classroom Hall Faucet AHS2 <b>Sampled:</b> 7/14/16 10:00						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	13.9	ppb	2.0	20 ppb	07/26/16 18:05
<b>6202072-03</b>	<b>Sample Name:</b> Classroom Hall Faucet AHS1 <b>Sampled:</b> 7/14/16 11:00						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	<b>32.7</b>	ppb	2.0	20 ppb	07/26/16 18:05 <b>MCLE</b>
<b>6202072-04</b>	<b>Sample Name:</b> Auditorium Hall Faucet AHS <b>Sampled:</b> 7/14/16 11:40						<b>Matrix:</b> Water
†Lead	1030	EPA 200.9	<b>24.8</b>	ppb	2.0	20 ppb	07/26/16 18:05 <b>MCLE</b>

**MCLE** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray  
Laboratory Director



13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional  
Laboratory  
Services**

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 06/28/2016

Received: 06/15/2016

Sampled By:  
Work Order: 6168034



**C** Astoria School District  
**L** Attn: -  
**I** 785 Alameda Ave.  
**E** Astoria OR, 97103  
**N** Phone: (503) 325-6441  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:

**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6168034-01</b>	<b>Sample Name:</b> AHS - Kitchen Sink <b>Sampled:</b> 6/14/16 7:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-02</b>	<b>Sample Name:</b> AHS - Sports Hall Faucet <b>Sampled:</b> 6/14/16 7:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	17.5	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-03</b>	<b>Sample Name:</b> AHS - Classroom Hall Faucet <b>Sampled:</b> 6/14/16 7:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	<b>83.6</b>	ppb	20.0	20 ppb	06/27/16 16:44 <b>MCLE</b>
<b>6168034-04</b>	<b>Sample Name:</b> AHS - Special Ed Room - Auditorium <b>Sampled:</b> 6/14/16 7:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-05</b>	<b>Sample Name:</b> LC - Kitchen Sink <b>Sampled:</b> 6/13/16 5:10		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-06</b>	<b>Sample Name:</b> LC - Staff Lounge <b>Sampled:</b> 6/13/16 5:55		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-07</b>	<b>Sample Name:</b> LC - Room #123 <b>Sampled:</b> 6/13/16 5:54		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-08</b>	<b>Sample Name:</b> LC - Room #209 <b>Sampled:</b> 6/13/16 5:45		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-09</b>	<b>Sample Name:</b> AMS - Staff Lounge <b>Sampled:</b> 6/13/16 5:28		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-10</b>	<b>Sample Name:</b> AMS - Gym Faucet <b>Sampled:</b> 6/13/16 5:44		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 06/28/2016  
Received: 06/15/2016  
Sampled By:  
Work Order: 6168034

**C** Astoria School District  
**L** Attn: -  
**I** 785 Alameda Ave.  
**E** Astoria OR, 97103  
**N** Phone: (503) 325-6441  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:



**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6168034-11</b>	<b>Sample Name:</b> AMS - Kitchen <b>Sampled:</b> 6/13/16 5:13		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.2	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-12</b>	<b>Sample Name:</b> AMS - Main Floor Faucet <b>Sampled:</b> 6/13/16 5:26		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-13</b>	<b>Sample Name:</b> Astor - Staff Lounge - 2nd <b>Sampled:</b> 6/13/16 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-14</b>	<b>Sample Name:</b> Astor - Gym Faucet <b>Sampled:</b> 6/13/16 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-15</b>	<b>Sample Name:</b> Astor - Kitchen <b>Sampled:</b> 6/13/16 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-16</b>	<b>Sample Name:</b> Astor - 3rd Floor Fountain <b>Sampled:</b> 6/13/16 5:00		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-17</b>	<b>Sample Name:</b> Gray - 3rd Floor - Lounge <b>Sampled:</b> 6/14/16 8:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-18</b>	<b>Sample Name:</b> Gray - Kitchen <b>Sampled:</b> 6/14/16 8:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-19</b>	<b>Sample Name:</b> Gray - Gym Faucet <b>Sampled:</b> 6/14/16 8:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	06/27/16 16:44
<b>6168034-20</b>	<b>Sample Name:</b> Gray - 2nd Floor Faucet <b>Sampled:</b> 6/14/16 8:30		<b>Matrix:</b> Water				
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**  
ORELAP Accredited Lab#: OR-100013

Reported: 06/28/2016  
Received: 06/15/2016  
Sampled By:  
Work Order: 6168034

**C** Astoria School District  
**L** Attn: -  
**I** 785 Alameda Ave.  
**E** Astoria OR, 97103  
**N** Phone: (503) 325-6441  
**T**

**Project:**  
Project # : N/A  
PWSID # :

Sampling Location:



**Lab Number**

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6168034-21	Sample Name: Transportation - Lounge (1L) Sampled: 6/13/16 8:30						Matrix: Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	06/27/16 16:44

**MCL** This analyte exceeds the MCL limit.

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is an action level for lead in samples based on a 100 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director



Oregon Department of Education  
 District Lead Testing Fixture Report Template

November 9, 2016

School District Name: Astoria School District  
 Dist ID: 1933

Building Name:	Fixture Location/Description	Fixture Use	Date of Test	Date of 1st Retest (If needed)	Date of 2nd Retest (If needed)	Date of 3rd Retest (If needed)	Cost per Test	Total # of Tests	Reimbursable Amount
Astoria High School	Kitchen	Food Prep	6/15/2016				\$20	1	20.00
Astoria High School	Sports Hall Faucet	Drinking	6/15/2016	7/14/2016	10/14/2016		20.00	3	60.00
Astoria High School	Classroom Hall Faucet 1	Drinking	6/15/2016	7/14/2016	10/14/2016		20.00	3	60.00
Astoria High School	Special Ed. Classroom	Other Human Consumption	6/15/2016				20.00	1	20.00
LC Elementary	Kitchen	Food Prep	6/15/2016				20.00	1	20.00
LC Elementary	Staff Lounge	Food Prep	6/15/2016				20.00	1	20.00
LC Elementary	Classroom #123	Drinking	6/15/2016				20.00	1	20.00
LC Elementary	Classroom #209	Drinking	6/15/2016				20.00	1	20.00
Astoria Middle School	Staff Lounge	Food Prep	6/15/2016				20.00	1	20.00
Astoria Middle School	Gym Faucet	Drinking	6/15/2016				20.00	1	20.00
Astoria Middle School	Kitchen	Food Prep	6/15/2016				20.00	1	20.00
Astoria Middle School	Main Floor Faucet	Drinking	6/15/2016				20.00	1	20.00
Astor Elemn	2nd Floor Staff Lounge	Food Prep	6/15/2016				20.00	1	20.00
Astor Elemn	Gym Faucet	Drinking	6/15/2016				20.00	1	20.00
Astor Elemn	Kitchen	Food Prep	6/15/2016				20.00	1	20.00
Astor Elemn	3rd Floor Faucet	Drinking	6/15/2016				20.00	1	20.00
Gray School	Kitchen	Food Prep	6/15/2016				20.00	1	20.00
Gray School	Gym Faucet	Drinking	6/15/2016				20.00	1	20.00
Gray School	2nd Floor Faucet	Drinking	6/15/2016				20.00	1	20.00
Transportation	Staff Lounge	Food Prep	6/15/2016				20.00	1	20.00
Astoria High School	Classroom Hall Faucet 2	Drinking	7/14/2016	10/14/2016			20.00	1	20.00
Astoria High School	Auditorium Hall Faucet 1	Drinking	7/14/2016	10/14/2016			20.00	2	40.00
Astoria High School	Sports Hall Faucet 2	Drinking	"10/14/2016				20.00	1	20.00
<b>Reimbursement Requested:</b>									<b>580.00</b>