

Water Testing Results - Astor Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	Corrective Action Taken
Staff Lounge	AST-001	6/13/2016	3.1 ppb	
Gym Faucet	AST-002	6/13/2016	ND	
Kitchen Sink Cafeteria	AST-003	6/13/2016	ND	
3rd Floor Fountain	AST-004	6/13/2016	2.7	

ND = Non Detect - Lead level is below the set detection limits