

## Water Testing Results - Capt Robert Gray

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result	Corrective Action Taken
3rd Floor Lounge	GRA-001	6/14/2006	ND	
Kitchen Sink Cafeteria	GRA-002	6/14/2006	ND	
Gym Faucet	GRA-003	6/14/2006	6.8 ppb	
2nd Floor Faucet	GRA-004	6/14/2006	ND	

ND = Non Detect - Lead level is below the set detection limits